Message

Sent: 4/14/2019 4:13:54 PM
To: Cheatham, Reggie [cheatham.reggie@epa.gov]; marti
Subject: FW: ITC Request For Discharge Authorization
Attachments: Request For Discharge Authorization.pdf; ATT00001.htm; Effluent Limitations and Monitoring Requirements.pdf; ATT00002.htm

From: Crossland, Ronnie
Sent: Saturday, April 13, 2019 10:13 PM
To: Gray, David <gray.david@epa.gov>
Cc: Edlund, Carl <edlund.carl@epa.gov>; Smith, Monica <smith.monica@epa.gov>
Subject: Fwd: ITC Request For Discharge Authorization

Sent from my iPhone

Begin forwarded message:

> **From:** Kelly Cook <kelly.cook@tceq.texas.gov>
> **Date:** April 13, 2019 at 8:54:35 PM CDT
> **To:** "Crossland, Ronnie (Crossland.Ronnie@epa.gov)" <Crossland.Ronnie@epa.gov>
> **Cc:** "Adams, Adam" <Adams.Adam@epa.gov>
> **Subject: ITC Request For Discharge Authorization**
>
> Ronnie,
> TCEQ supports EPA moving forward in approving ITC's April 13, 2019 Request for One-time Authorization of Discharge of Incident Related Wastewater and Continuing Discharge of Non-Incident Related Wastewater as set forth in that request and under the following conditions:
>
> 1) the bench scale treatability study provided to TCEQ and EPA on April 7, 2019 is representative of the contents of the wastewater treatment storage tank 80-34 which is the subject of ITC's request;
>
> 2) any discharge of incident related wastewater complies with TPDES permit no. 0001984000, in addition to the limitations in the attached table entitled: *Effluent Limitations and Monitoring Requirements;*
>
> 3) TCEQ and EPA will need to provide concurrence after reviewing sampling data of the treated wastewater from tank 80-34 prior to routing any additional waste streams to the wastewater treatment plant including non-incident wastewater; and,
>
> 4) ITC has been, and will continue to, diligently pursue additional options to manage the wastewater that has accumulated as a result of the fire suppression efforts in response to the incident that began at the facility on March 17, 2019.
>
> TCEQ understands that prompt action on this request is necessary to allow an expeditious and controlled means of creating additional storage capacity through treatment and discharge of the tank contents.